Cap

310B-33XXX

4.0" O.D.
Galvanized Pipe

300B-33XXX

12 Feet

Gnd. Lug &
Wire

6 to 8 Feet

300B-33XXX

BX 20
Junction Box (Optional)

1/2" Flexible Conduit

36" Nominal

310B-33XXX

17" Nominal

12" Nominal

#6 AWG
Ground Bus

Grounding
Rod
per Local
Electrical Code

Concrete Base
As Required by
Site

24" to 36" Typical

Install Per Local
Electrical Code

Tamper, Alarm and Power Lines

7 IN.
177 mm

4.5 in.
115 mm

This Document Is For Reference Only.

TITLE	Quad Stack Microwave with MB65 Mounting Bracket - Typical		
SCALE	NTS		
DRAWN	TG	DATE	February 23, 2007